

Coast Guard, DHS

§ 118.300

160.156 is acceptable in meeting the intent of this section. On a vessel of not more than 19.8 meters (65 feet) in length, a required rescue boat must be acceptable to the cognizant OCMI.

[CGD 85-080, 61 FR 911, Jan. 10, 1996, as amended at 62 FR 51351, Sept. 30, 1997; 62 FR 64305, Dec. 5, 1997]

PART 118—FIRE PROTECTION EQUIPMENT

Subpart A—General Provisions

Sec.

118.115 Applicability to existing vessels.

118.120 Equipment installed but not required.

Subpart B [Reserved]

Subpart C—Fire Main System

118.300 Fire pumps.

118.310 Fire main and hydrants.

118.320 Fire hoses and nozzles.

Subpart D—Fixed Fire Extinguishing and Detecting Systems

118.400 Where required.

118.410 Fixed gas fire extinguishing systems.

118.420 Pre-engineered fixed gas fire extinguishing systems.

118.425 Galley hood fire extinguishing systems.

Subpart E—Portable Fire Extinguishers

118.500 Required number, type, and location.

118.520 Installation and location.

Subpart F—Additional Equipment

118.600 Fire axe.

AUTHORITY: 46 U.S.C. 2103, 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; Department of Homeland Security Delegation No. 0170.1.

SOURCE: CGD 85-080, 61 FR 917, Jan. 10, 1996, unless otherwise noted.

Subpart A—General Provisions

§ 118.115 Applicability to existing vessels.

(a) Except as otherwise required by paragraphs (b) and (c) of this section, an existing vessel must comply with the fire protection equipment regulations applicable to the vessel on March

10, 1996, or, as an alternative, the vessel may comply with the regulation in this part.

(b) An existing vessel with a hull, or a machinery space boundary bulkhead or deck, composed of wood or fiber reinforced plastic, or sheathed on the interior in fiber reinforced plastic, must comply with the requirements of § 118.400 of this part on or before March 11, 1999.

(c) New installations of fire protection equipment on an existing vessel, which are completed to the satisfaction of the cognizant Officer in Charge, Marine Inspection (OCMI) on or after March 11, 1996, must comply with the regulations of this part. Replacement of existing equipment installed on the vessel prior to March 11, 1996, need not comply with the regulations in this part.

§ 118.120 Equipment installed but not required.

Fire extinguishing and detecting equipment installed on a vessel in excess of the requirements of §§ 118.400 and 118.500 of this part must be designed, constructed, installed and maintained in a manner acceptable to the Commandant.

Subpart B [Reserved]

Subpart C—Fire Main System

§ 118.300 Fire pumps.

(a) A self priming, power driven fire pump must be installed on each vessel.

(b) On a vessel without overnight accommodations, or with overnight accommodations for not more than 49 passengers, the fire pump must be capable of delivering a single hose stream from the highest hydrant, through the hose and nozzle required by § 118.320 of this part, at a pitot tube pressure of 345 kPa (50 psi).

(c) On a vessel carrying more than 600 passengers or with overnight accommodations for more than 49 passengers, the fire pump must meet § 76.10-5 of this chapter.

(d) A fire pump may be driven by a propulsion engine. A fire pump must be permanently connected to the fire main and may be connected to the

§ 118.310

bilge system to meet the requirements of § 119.520 of this subchapter.

(e) A fire pump must be capable of both remote operation from the operating station and local operation at the pump.

[CGD 85-080, 61 FR 917, Jan. 10, 1996; 61 FR 20556, May 7, 1996, as amended at 62 FR 51351, Sept. 30, 1997]

§ 118.310 Fire main and hydrants.

(a) Except as required by paragraph (d) of this section, a vessel must have a sufficient number of fire hydrants to reach any part of the vessel using a single length of fire hose.

(b) Piping, valves, and fittings in a fire main system must comply with part 119, subpart G of this subchapter.

(c) Each fire hydrant must have a valve installed to allow the fire hose to be removed while the fire main is under pressure.

(d) On a vessel carrying more than 600 passengers or with overnight accommodations for more than 49 passengers, the fire main and hydrants must meet § 76.10-10 of this chapter.

[CGD 85-080, 61 FR 917, Jan. 10, 1996, as amended at 62 FR 51351, Sept. 30, 1997]

§ 118.320 Fire hoses and nozzles.

(a) A fire hose with a nozzle must be attached to each fire hydrant at all times. For fire hydrants located on open decks or cargo decks, where no protection is provided, hoses may be temporarily removed during heavy weather or cargo handling operations, respectively. Hoses so removed must be stored in nearby accessible locations.

(b) Each hose must:

(1) Be lined commercial fire hose that conforms to Underwriters Laboratory (UL) 19 "Lined Fire Hose and Hose Assemblies," or hose that is listed and labeled by an independent laboratory recognized by the Commandant as being equivalent in performance;

(2) Be 15.25 meters (50 feet) in length and 40 millimeters (1.5 inches) in diameter; and

(3) Have fittings of brass or other suitable corrosion-resistant material that comply with National Fire Protection Association (NFPA) 1963 "Fire Hose Connections," or other standard specified by the Commandant.

(c) Each nozzle must either:

46 CFR Ch. I (10-1-11 Edition)

(1) Be of a type approved in accordance with approval series 162.027; or

(2) Be of type recognized by the Commandant as being equivalent in performance.

[CGD 85-080, 61 FR 917, Jan. 10, 1996; 61 FR 24464, May 15, 1996, as amended at 62 FR 51351, Sept. 30, 1997; 62 FR 64305, Dec. 5, 1997]

Subpart D—Fixed Fire Extinguishing and Detecting Systems

§ 118.400 Where required.

(a) The following spaces must be equipped with a fixed gas fire extinguishing system, in compliance with § 118.410 of this part, or other fixed fire extinguishing system specifically approved by the Commandant, except as otherwise allowed by paragraph (b) of this section:

(1) A space containing propulsion machinery;

(2) A space containing an internal combustion engine of more than 50 hp;

(3) A space containing an oil fired boiler;

(4) A space containing combustible cargo or ship's stores inaccessible during the voyage (a carbon dioxide system must be installed in such a space, and Halon systems are not allowed);

(5) A paint locker; and

(6) A storeroom containing flammable liquids (including liquors of 80 proof or higher where liquor is packaged in individual containers of 9.5 liters (2.5 gallons) capacity or greater).

(b) Alternative system types and exceptions to the requirements of paragraph (a) of this section are:

(1) A fixed gas fire extinguishing system, which is capable of automatic discharge upon heat detection, may only be installed in a normally unoccupied space with a gross volume of not more than 170 cubic meters (6,000 cubic feet);

(2) A pre-engineered fixed gas extinguishing system must be in compliance with § 118.420 of this part and may only be installed in a normally unoccupied machinery space, a paint locker, or a storeroom containing flammable liquids (including liquors of 80 proof or higher where liquor is packaged in individual containers of 9.5 liters (2.5 gallons) capacity or greater), with a gross